



HARGROUND™

High Compression Grounding Series CGFEXCR

Catalog Number	Cable to Ground Rod ① / Reinforcing Steel ②		Installation Data (A, B)	
	Conductor Range (A)	Ground Rod Range / Reinforcing Steel Range (B)	Die Index	No. of Crimps
CGFEXCR250212	#2 Str. - 250 MCM	1/2" / #3 - #4 Reinforcing Steel	U997, U998	1
CGFEXCR50025012	250 MCM - 500 MCM	1/2" / #3 - #4 Reinforcing Steel	U998	1
CGFEXCR250258	#2 Str. - 250 MCM	5/8" / #5 - #6 Reinforcing Steel	U997, U998	1
CGFEXCR50025058	250 MCM - 500 MCM	5/8" / #5 - #6 Reinforcing Steel	U998	1
CGFEXCR250234	#2 Str. - 250 MCM	3/4" / #5 - #6 Reinforcing Steel	U997, U998	1
CGFEXCR50025034	250 MCM - 500 MCM	3/4" / #5 - #6 Reinforcing Steel	U998	1

* A 12-ton tool is required for these connections.

① Ground Rods must be precrimped. See below for die chart.

Ground Rod Dia.	Precrimping Dies
1/2"	U2CABT
5/8"	U2CABT
3/4"	U2CABT



② Clean rust and protective coatings from reinforcing steel prior to installation to provide proper ground connection. Precrimping is not required.