




Top View



Bottom View



#IBTD Intersystem Bonding Termination Device

DESCRIPTION

- Accepts one 6-1 AWG Grounding electrode conductor, four 14-4 AWG Bonding conductors and one Class I copper Lightning conductor.
- Slide in, snap fit lid design for easy installation and inspection.
- Meets the requirements of 2008 NEC Article 250.94.

APPLICATION

- An external accessible intersystem bonding termination for connecting intersystem bonding and grounding conductors at the service equipment and at the disconnection means for any additional buildings or structures.*

* 2008 NEC Article 250.94

301 Ziegler Drive, Grayslake, IL 60030
847-548-8700 • 800-842-7437 • Fax: 847-548-8755
Web-site: www.harger.com • E-mail: hargersales@harger.com